



ELECTRICAL CONDUIT RIGID ENTRY BOOTS

APT™ rigid entry boots allow you to connect electrical conduit to containment sumps with a significant reduction in installation time, while also completely removing exposed rubber from the connection. This durable entry boot requires only a single 2.75" entry hole for installation, removing the time-consuming process of drilling multiple holes for fastening purposes.

HIGHLIGHTS

- Design requires only a single 2.75" entry hole offering a significant reduction in installation time.
- Features a dual-seal design that will work with either galvanized or coated conduit.
- Suitable for use with flat and round sump surfaces and polyethylene or fiberglass sumps.
- Clamp plate and two gasketed face seal and pipe seal material: Nitrile seals ensure a watertight connection.

ORDERING INFORMATION

Each size of rigid entry boot utilizes the same body allowing you to switch out the conduit seal to fit different pipe sizes in the field if necessary.

Model	Description
REB-C-0075	¾" rigid entry boot for flat sump surfaces
REB-C-0100	1" rigid entry boot for flat sump surfaces
REB-C-R-0075	¾" rigid entry boot for round sump surfaces
REB-C-R-0100	1" rigid entry boot for round sump surfaces
408066001	Conduit seal ¾" (replacement)
408066002	Conduit seal 1" (replacement)
408070001	Clamping seal (flat) (replacement)
408072001	Clamping seal (round) (replacement)
408073001*	Plastic adapter for curved sump (one per rigid boot entry)

*Used to convert a flat sump surface rigid entry boot into a round sump surface rigid entry boot.

SPECIFICATIONS

- Body material: glass-filled nylon
- Clamp nut and nut material: glass-filled nylon
- Face seal and pipe seal material: Nitrile
- Interior length once installed: 3¼"

Approvals/Certifications

- ULC listed when installed with APT™ ULC listed sumps.

Installation

A clamping nut and two clamping seals are used to compress the fitting into place against the sump wall simply by tightening it into place, providing a watertight connection between the boot and the sump surface. The same method is used to seal the pipe into place simply by tightening the integrated conduit seal nut.

- 1 Electrical conduit rigid entry boot
- 2 Electrical conduit

